



# REVIEW OF HPP ZHUR FEASIBILITY STUDY INCLUDING PREPARATION OF PRELIMINARY EIA AND PRELIMINARY SA



**elektroprojekt**  
*Established 1949*  
Consulting Engineers

Alexandra von Humboldtta 4  
10000 Zagreb  
CROATIA  
[www.elektroprojekt.hr](http://www.elektroprojekt.hr)



REPUBLIKA E KOSOVËS  
REPUBLIKA KOSOVA  
REPUBLIC OF KOSOVO

Ministria e Energjisë dhe Minierave  
Ministarstvo energije i rudarstva  
Ministry of Energy and Mining

LPTAP Project Office



The  
World  
Bank



# THE TASKS

- Task 1:** Review and update the existing hydrological, hydro-technical, and geological data for necessary for development of HPP Zhur.
- Task 2:** Review, update and optimize **plant installed capacity** and update/complete the existing **preliminary engineering design** of the HPP Zhur;
- Task 3:** Review and update/complete the existing **financial and economic feasibility** of the HPP Zhur, including analysis of financing options;
- Task 4:** Prepare a preliminary EIA (**Environmental Impact Assessment**), including trans-boundary impacts, impact on downstream irrigation and dam safety associated international requirements;
- Task 5:** Prepare a preliminary SA (**Social Assessment**), including a draft Resettlement Action Plan.



# collecting of necessary documentation and input data

- **available documentation:**

- ✓ Feasibility Study, Elektroprojekt Consulting Engineers, Zagreb 2001,
- ✓ Zhur HPP, Preliminary Design, Kosovoprojekt Beograd 1970 – not complete,
- ✓ HPP Zhur, The Plavë River Dam – Discharge Structures Selection, Elektroprojekt Consulting Engineers Zagreb 1986,
- ✓ HPP Zhur I, Analysis and Selection of Cost Effective Surge Tank, Elektroprojekt Consulting Engineers Zagreb 1986,
- ✓ HPP Zhur, The Brezna (Lopuško polje – *Fusha e Llopushnikut*) Reservoir Conceptual Design Update, Volumes I and II, Elektroprojekt Consulting Engineers, Zagreb 1983,
- ✓ HPP Zhur Geological and Hydrogeological Relations at the Fusha e Llopushnikut Area,
- ✓ Study on Engineering Geology and Hydrogeology of the Çaljana and Restelic Rivers Conveyance System and Dam Site and the Plavë Reservoir Dam Area, 1985,
- ✓ HPP Zhur - Reinterpretation of Investigation Results, Volumes I and II, Elektroprojekt Consulting Engineers, Zagreb, 1984,
- ✓ Basic Geological Map, Prizren sheet, scale 1:100,000,
- ✓ HPP Zhur Final Design, Geology, Brod River Engineering Geology along the Conveyance System Route Zagreb, 1986,
- ✓ Analysis of Seismic Hazards and Defining of Design Seismic Parameters for the HPP Zhur System Structures, IZIS, Skopje, 1986,
- ✓ HPP Zhur Hydrological Input Data and Documentation, Elektroprojekt Consulting Engineers, Zagreb 1986,
- ✓ Land surveying maps, scale 1:25,000

# collecting of necessary documentation and input data

- requested documentation (2-3 November 2008) **MEETINGS HELD AT:**
  - Prizren Municipality,
  - Dragash/Sharr Municipality,
  - Ministry of Environment and Spatial Planning,
  - Ministry of Culture, Youth and Sports,
  - Ministry of Agriculture, Forestry and Rural Development,
  - Ministry of Labor and Social Welfare,
  - Hydro-meteorological Institute of Kosovo

• received documentation is rather modest

elektroprojekt d.d. • zagreb				Type	Design	Volume	Section 003
				Y1	K74.00.02	G01.0	Page 3
3	<b>BACKGROUND DOCUMENTATION</b>						
3.1	<b>OVERVIEW OF DOCUMENTATION REQUIRED FOR THE HPP ZHUR PROJECT</b>						
Within this task (TASK 1), it is planned to collect documentation and input data needed for performance of contracted work. An overview of documentation was prepared, as below:							
1. The HPP Zhur Design documentation has not been developed.							
2. Other design documentation related to HPP Zhur Project							
1 WB Energy Sector Technical Assistance Projects (ESTAP 1, 2 & 3);							
2 Feasibility Study for 400 KV interconnection line between Kosovo and Albania;							
3 WB Light Power TA Project (LTPAT);							
4 Kosovo Irrigation Rehabilitation Plan, KIRP I and KIRP II reports;							
5 Modern, or Tertiary, Irrigation Project (available on request in MAFRD);							
6 WB/FAO Capacity Building Component of Emergency Farm Reconstruction Project: Water Resource Management Study (including a review of the Water Master Plan for Kosovo), and Irrigation Rehabilitation Study (available on request to MAFRD);							
7 Water Master Plan of Kosovo, 1985;							
8 Water Balance Report, IIMPH, 2004;							
9 Assessment of small hydropower resources of Kosovo, 2006 (available on request in MEM);							
3. Hydro-meteorology							
For observation and measurement period 1978-2007:							
<b>Weather input data – monthly and annual values:</b>							
1 Precipitation at stations: Prizren, Zhur, Zapluzh, Dragash, Restenica, Rečan and Brod Gorski							
2 Air temperature: Dragash and Prizren;							
3 Wind: Dragash, Prizren and Prizhine;							
4 Relative humidity and evaporation: Dragash and Prizren.							
<b>Hydrology input data:</b>							
1 Mean and extreme daily, monthly and annual water levels and flow rates, data on measured flow rates at the stations located at respective rivers: Mike, Brotska Raka River, Krušeno, Restenicka Raka River, Ortula, Pivacka Raka River, Zym and Rapica, Pivacka Raka River							
4	<b>Agreement between SFR Yugoslavia and Albania on Obligation to Discharge Water from the Zhur Station towards Albania</b>						
1 An Agreement reached by the Yugoslav Albanian Commission in 1962, according to which all the water from the Cakanska River flows freely to Albania in July and August. For the Pivacka Raka, a discharge of 1 250 000m <sup>3</sup> was agreed for July and 2 500 000 m <sup>3</sup> for August.							
5	<b>Connection to Grid</b>						
1 Configuration of the 400 KV, 220 KV and 110 KV Kosovo Transmission System with appropriate substations and power production facilities (thermal and hydro power plants)							
2 220/110 KV PRIZREN Substation, i.e. possible connection point (Single-line diagram, Technical Data on 220 KV and 110 KV Equipment, Technical Data on Main Transformers, Number of 220 KV and 110 KV Transmission Lines connected to the PRIZREN Substation, i.e. possible connection points, Technical Data on Transmission Lines – transmission line length, line cross-sections, appropriate 220 KV substations connected to the PRIZREN Substation, i.e. possible connection point,							
3 Power flow direction from the Prizren Substation, i.e. possible connection point to 220 KV and 110 KV voltage levels							
4 Three and single pole short circuit current on 220 KV busbars in PRIZREN Substation, i.e. possible connection point							
5 XOST – procedures and agreements							
6 Transmission System Development Study							

elektroprojekt d.d. • zagreb				Type	Design	Volume	Section 003
				Y1	K74.00.02	G01.0	Page 4
2	<b>Planned system workforce and salaries</b>						
Data on charges and taxes payable under the law charges (land utilization, water utilization, etc.), insurance premiums, depreciation, taxes (VAT and profit tax), custom duties and other import costs							
4 Price of base and variable electricity to be used in benefit calculation (acc. to the Kosovo tariff system)							
5 IEX Annual Report							
7	<b>GIS and SA</b>						
Prizren Municipality Physical Plan							
Dragash Municipality Physical Plan							
State-of-the-Space Use Report							
The below list of documents is for the Prizren and Dragash Municipalities area affected by the project:							
<b>Spielogical characteristics of the area under consideration</b>							
1 Identification and position of spelogical features in immediate vicinity and under the planned tunnels							
2 Description of spelogical features							
3 Position of spelogical features							
4 Layout of spelogical features							
5 Profile of spelogical features							
<b>Soil and arable land in the area under consideration</b>							
1 Geographical position of the area under consideration							
2 General soil cover characteristics in the area under consideration							
3 Soil production potential and quality evaluation							
4 Vegetation cover without forests							
5 Land use and water demand							
6 State of plant production and animal breeding							
7 Soil map							
8 Soil map indicating suitability for agriculture							
<b>Forest ecosystems and forestry in the area under consideration</b>							
1 Surface area and arrangement of forests and forestland							
2 Present state of the forests							
3 Forestland characteristics							
4 Vegetation cover							
5 Typological analysis							
6 Stand forest value							
7 Production and allowable felling							
8 Stand renewal value							
9 Forest ecological function and value assessment							
10 Forest threats assessment							
11 Rare, endangered and protected spaces							
12 Forest communities map							
13 Forest stand classification map							
14 Forest stand classification map							
<b>Game and hunting in the area under consideration</b>							
1 Game state							
2 Hunting organization							
3 Hunting grounds map							

elektroprojekt d.d. • zagreb				Type	Design	Volume	Section 003
				Y1	K74.00.02	G01.0	Page 5
<b>Land fauna in the area under consideration</b>							
1 Invertebrata							
1.1 Fish fund structure							
1.2 Ichthyoproducts							
1.3 Fishing area use							
1.4 Rare, endangered and protected spaces							
2 Terrestrial fauna							
2.1 Invertebrata characteristics							
2.1.1 Extent of occurrence of main groups and systematic presentation							
2.1.2 Rare, endangered and protected spaces							
2.2 Vertebrata characteristics							
2.2.1 Characteristics of reptiles, amphibians, birds and mammals							
2.2.1.1 Extent of occurrence and systematic presentation							
2.2.1.2 Vertebrata habitats							
2.2.1.3 Rare, endangered and protected spaces							
<b>Characteristics of vegetation in the area under consideration</b>							
1 Presentation of diversity of habitats, vegetation and flora							
1.1 Exclusively suitable habitats							
1.2 Spatial distribution of communities							
1.2.1 Wetland habitat communities							
1.2.2 Terrestrial habitat communities							
2 Taxa diversity valuation							
2.1 Evidence (endangered and not endangered)							
2.2 Rare, endangered and protected spaces							
2.3 Endangered population							
3 Area vegetation maps, scale 1: 100 000							
<b>Characteristics of land and aquatic ecosystems and terrestrial ecosystems</b>							
1 Physico-chemical characteristics							
2 Biological and bacteriological characteristics, without ichthyofauna							
3 Water quality assessment							
<b>Cultural and historical assets</b>							
1 General data							
1.1 Basic characteristics of the area							
1.2 Historical overview							
2 Analysis of the present state							
2.1 Analysis of cultural and historical assets							
2.1.1 Archaeological sites							
2.1.2 Settlements							
2.1.3 Individual monuments							
2.1.4 Other potential assets							
2.2 Degree of research							
2.3 Availability of documented area records							
3 Identification of cultural and historical assets							
regional							
recoiled							
assumed							
<b>Demographic aspects</b>							
1 Population rate trends							
1.1 Population distribution and density							
2 Population rate trends projection by 2027							
3 Biological and socioeconomic structure of population							
4 Basic positive/negative determinants of demographic aspects							


elektroprojekt d.d. • zagreb				Type	Design	Volume	Section 003
				Y1	K74.00.02	G01.0	Page 6
<b>Landscape characteristics</b>							
1 Landscape units in the area under consideration							
1.1 Analysis of natural and cultural landscape elements							
1.1.1 Geographic characteristics							
1.1.2 Vegetation characteristics							
1.1.3 Interventions in the overall area							
1.2 Evaluation of landscape and environmental assets							
2 Landscape units spatial distribution map							
3 Map of landscape assets to be lost							
<b>Basic Required Information – SA</b>							
Basic required information – documentation							
List of settlements – villages in the area affected by the project							
– municipality borders / administrative borders, if passing through the area, administration seats							
Assessed or exact population in the area affected by the project							
Number of families, average number of family members and family structure							
Number of children							
– literacy (percentage), education structure (secondary, higher, university)							
Number of working persons per household							
Number and type of housing units							
– average house floor and garden area							
Number and structure of property (plough land, meadows, forests, etc.)							
Estimated value of different types of land in the area affected by the project							
– estimated market value of estate (houses, plough land, meadows)							
– estimated yield of concrete plants per hectare of plough land							
– revenue estimate (yield x sale price – cultivation costs)							
– leaves (net estate trade, arable land, income)							
– social income (if any – child allowance, unemployment benefits)							
– water management authority charges (e.g. water abstraction charges), if any							
Number, types and evaluation of value of cattle (average, per household)							
Communications, local road and water sources in the area affected by the project – compensation (replacement) options							
Number, location and evaluation of potential replacement land							
Structure of population employment in the area affected by the project							
National structure of population in the area affected by the project							
– position of sacral buildings in the project area – if any							
– position of schools, types of schools, number of classrooms and teachers in settlements at the Project area and in its vicinity							
Population income breakdown							
Level of information of local population on hydroelectric power plant construction plans							
List of protected cultural assets in the area affected by the project							
List of essential municipal utility services – sewerage, electricity, power production							
– infrastructure layout							
– state of roads in the Project area (asphalt, macadam, ...)							
Availability of town and physical planning documentation							
Most frequent information dissemination methods (local radio, TV, newspapers) and marketing prices (advertisements per page and per minute used for information dissemination, cost estimate)							
<b>Basic research implementation conditions – SA</b>							
Availability of data from cadastral and land records							
Availability of personnel (number, qualifications) for surveying – housing units, number of household members, occupation, kind and type of ownership, heads of cattle, household facilities, attitudes towards relocation and variation of relocation preferred by local population, etc. in the area affected by the project							
Availability of qualified conference interpreters							
Availability of meeting rooms							
Availability of different technical support							



# collecting of necessary documentation and input data

## OBLIGATIONS TOWARDS ALBANIA

- **water** for power generation at the HPP Zhur is harnessed from the watercourses **shared by Kosova and Albania**
- in line with the **Espoo Convention**, the competent ministry of the Republic of Kosova notified the competent ministry of the Republic of Albania about the planned HPP Zhur Project
- the notification letter highlights the need for determination of the **environmentally acceptable flow (EAF)** in streams downstream from the water intakes
- a contact **has been established** between the relevant authorities of the Republic of Kosova and the Republic of Albania regarding the transboundary issues. **This is an ongoing cooperation.**







On several occasions, representatives of Elektroprojekt and LPTAP Project Office made a tour of an area planned for construction of the HPP Zhur. The site visits were organized for:

1. Determining the **on-site conditions** and their impact on technical concepts from the 2001 Feasibility Study,
2. Checking **morphology of streams** to be harnessed and their catchments in order to assess hydrological parameters and data,
3. Checking the **ecological state** of the streams to be harnessed for assessment of the environmentally acceptable flow to be provided in the stream channel after the Project completion.



*View of houses to be impounded from the Plavě reservoir*






*The Lumi Plavë River, downstream view from the former gauging station location*




*The Plavë reservoir – view of dam site*



*View of the Lumi Xerxë River upstream from the Zhur – Dragash/Sharr road bridge*



*Mouth of the Lumi Xerxë into the Lumi Plavë River*







*The Lumi Radeshë River –  
state of the environment*



*The Lumi Leshtani river –  
state of the environment*



*The Lumi Brod River – downstream view from the  
road with the Lugina Marinit stream mouth*



*The Lumi Restelic River near Krushevë*







*View of Fusha e Llopushnikut field – Brezna settlement in the back*






The **Fusha e Llopushnikut** area suffered considerable changes in space compared to the situation described in design documentation from 1983 (???). **The settlement of Brezna expanded in direction of the Fusha e Llopushnikut** planned to be occupied by the reservoir. The site survey also revealed expansion of the settlement of **Hani i Llopushnikut**, all of which will be impounded.






*View of Zhur village*




*Conceptual  
design route  
(1970)*



The conveyance system could come into **conflict with the recently built houses and structures** in a section near Dragash/Sharr





- HPP Zhur project will be situated in a location with **different lithological and engineering geology characteristics**, **Analysis of Seismic Hazards and Defining of Design Seismic Parameters for the HPP Zhur System Structures**, IZIS, Skopje, 1986:
  - there are **no reasons for relocation** of the planned conveyance system route,
  - the **Playë and Brezna reservoirs are feasible**.
- **IZIS study** + supporting documentation → structural calculation according to **EUROCODE 8**
- preparation of the final designs requires **additional investigations and tests**







- hydrological documentation and input data for the period **1925/26 – 1978/79** were prepared by Elektroprojekt Consulting Engineers, Zagreb in May 1986,

## **HYDROLOGY ANALYSIS SUMMARY (2008)**

- in February 2009 additional data were received and consultations carried out – Hydro-Meteorological Institute of Kosova for period 2003 – 2008 (not complete)
- there are no significant changes compared to the analysis prepared in 1986
- analysis results from 1986 are realistic for the period under consideration.**



## ZHUR HPP CATCHMENT AREAS







- all the conclusions are made on the basis of analyses given in the documentation under consideration (1925/26 – 1978/79)

- *maximum flow rates of different recurrence periods*
- *mean annual flows:*

• Lumi Çaljane River	$Q_{\text{mean}} = 0.854 \text{ m}^3/\text{s}$
• Lumi Restelic River	$Q_{\text{mean}} = 2.320 \text{ m}^3/\text{s}$
• Lumi Brod River	$Q_{\text{mean}} = 2.380 \text{ m}^3/\text{s}$
• Procka Baç	$Q_{\text{mean}} = 0.042 \text{ m}^3/\text{s}$
• Lugina Veliut	$Q_{\text{mean}} = 0.024 \text{ m}^3/\text{s}$
• Lugina Marinit	$Q_{\text{mean}} = 0.054 \text{ m}^3/\text{s}$
• Procka Lubivie	$Q_{\text{mean}} = 0.027 \text{ m}^3/\text{s}$
• Lumi Leshtani River	$Q_{\text{mean}} = 0.159 \text{ m}^3/\text{s}$
• Lumi Radeshe River	$Q_{\text{mean}} = 0.731 \text{ m}^3/\text{s}$
• Lumi Xërxë River	$Q_{\text{mean}} = 0.048 \text{ m}^3/\text{s}$

1986

- *minimum flow rates of different recurrence periods*

2008

- recommendations:
  - **set up hydrological stations** in points where water intakes are located
  - **urgently initiate systematic hydrological observations and measurements**





The only land surveying documentation available are **topographic maps (scale 1:25,000)** prepared **during the seventies of the 20th century**.

Those are good orientational maps for assessment of set up concepts.

For preparation of design documentation it will be necessary to survey:

- the Brezna Reservoir site
- the Plavë Reservoir site
- the Plavë River dam site, conveyance route, the sites planned for implementation of ground sealing, the sites planned for the HPP Zhur I and HPP Zhur II powerhouses, and the sites planned for the penstock and conveyance system route section from the HPP Zhur I to the HPP Zhur II
- the tunnel entries and exits, aqueducts, siphons, and the headrace canal route entry into and exit from the tunnel connecting the Plavë River reservoir and the Brezna Reservoir, the entrance into the headrace tunnel facing the HPP Zhur I powerhouse
- the Zym/Qollopek and Brezna settlements and all the houses and structures to be impounded need to be surveyed separately.









# THE TASKS

- Task 1:** Review and update the existing hydrological, hydro-technical, and geological data for necessary for development of HPP Zhur.
- Task 2:** Review, update and optimize **plant installed capacity** and update/complete the existing **preliminary engineering design** of the HPP Zhur;
- Task 3:** Review and update/complete the existing **financial and economic feasibility** of the HPP Zhur, including analysis of financing options;
- Task 4:** Prepare a preliminary EIA (**Environmental Impact Assessment**), including trans-boundary impacts, impact on downstream irrigation and dam safety associated international requirements;
- Task 5:** Prepare a preliminary SA (**Social Assessment**), including a draft Resettlement Action Plan.



**Task 2 Report** includes results of review, evaluation and modification of the HPP Zhur concept with rated discharge of  $Q_r = 50 \text{ m}^3/\text{s}$ , as envisaged by the Conceptual Design by Kosovoprojekt in 1970 and Feasibility Study prepared by Elektroprojekt Consulting Engineers in 2001, and it presents:

- a review of the earlier concepts, possible improvements/optimization and proposal for the concept modifications due to current site state;
- summary description of the proposed technical concepts with system basic drawings;
- cost estimate and plant output update.








## 1. Change in the HPP Zhur I location

- considerable changes have happened at the HPP Zhur I powerhouse site compared to the ones described in the Conceptual Design from 1970 – **a new powerhouse site needed to be determined**

(An idea to relocate the HPP Zhur I powerhouse in order to optimize the Project concept was considered in the eighties.)

- the HPP Zhur I powerhouse site proposed in the eighties is still **suitable**
- it is necessary to place the powerhouse at an **elevation which is approx. 13 m lower** than the elevation from the 1970 Conceptual Design.





### 2. Conveyance system


- Having in mind the new powerhouse site which was found adequate even in the present conditions, **two conveyance system routes** from the Brezna Reservoir were considered – the so called **“old”** and **“new” route**
- in order **to reduce the surge tank size** and, consequently, **investment costs** the conveyance system route was moved towards south (**“old” → “new”**), so that the upper chamber could be located at higher elevation (approx. 1000 m a.s.l.). The inlet structure and powerhouse of the HPP Zhur I would remain in the same position
- The study considered different types of upper chamber (**four upper chamber alternatives at the old route** and **six upper chamber alternatives at the new route**), while the lower chamber was planned to be shaped as horizontal tunnel

Route	“Old” route				“New” route					
Surge tank alternative	“a”	“b”	“c”	“d”	“a”	“b”	“c”	“d”	“e”	“f”
% of cost	100.00	100.22	100.76	100.15	99.10	99.14	100.26	100.18	99.84	99.14
Ranking	5 <sup>th</sup>	8 <sup>th</sup>	10 <sup>th</sup>	6 <sup>th</sup>	1 <sup>st</sup>	2 <sup>nd</sup> /3 <sup>rd</sup>	9 <sup>th</sup>	7 <sup>th</sup>	4 <sup>th</sup>	2 <sup>nd</sup> /3 <sup>rd</sup>






## 2. Conveyance system (cont'd)



animals into the shaft and only slightly more expensive than the alternative “a”.



## 1. HPP Zhur I – HPP Zhur II conveyance system



Water harnessed at the HPP Zhur I could be conveyed to the HPP Zhur II surge tank by **canals, tunnels and combination of these structures.**

Analysis of possible solutions resulted in **two alternative conveyance systems for the HPP Zhur II:**

**Alternative 1 (“tunnel”)** envisages a connection between the HPP Zhur I discharge basin and the HPP Zhur II surge tank by:

- **closed canal**, 520 m long
- **tunnel**, 1835 m long
- **open canal**, 560 m long

**Alternative 2 (“canal”)** envisages a connection between the HPP Zhur I discharge basin and HPP Zhur II surge tank by:

- **closed canal**, 520 m long
- **open canal**, 3210 m long





## 1. Conveyance system (cont'd)

	<i>Alternative 1 – “Tunnel”</i>	<i>Alternative 2 – “Canal”</i>
<i>Disadvantages</i>	N/A	<ul style="list-style-type: none"><li>• limited availability of space because of the road running on the left side of the canal,</li><li>• integration of the discharge system into the environment is much less successful than for the tunnel system,</li><li>• as regards possible geotechnical risks, the canal is less reliable technical solution than the tunnel,</li><li>• groundwater occurrence could cause uplift and any modifications would result in increase in price of this alternative,</li><li>• open canal is exposed to unfavorable conditions.</li></ul>
<b>Cost</b>	<b>€ 9,359,000.00</b>	<b>€ 10,890,000.00 *</b>

\* the above costs need to be added:

- the costs of construction of an access road to be built along the canal for its maintenance (**≈€ 450,000**),
- the land expropriation cost (**≈€ 25,000**),
- concession, compensation for query closing, if necessary, or communication across the canal if the query will continue to work (**€ ??**)!




## 2. TG sets number analysis

Since the HPP Zhur II operation is in direct relation with operation of the HPP Zhur I, which has two TG sets  $Q_i = 25 \text{ m}^3/\text{s}$  each, an question is raised of **whether installation of two TG sets in the HPP Zhur II powerhouse is justified.**


As a peaking power plant, the HPP Zhur will successfully:

- shave variable parts of the daily load diagram and/or
- intervene providing safe supply to the customers in case of thermal power plants outages.

If only one TG set is installed in HPP Zhur II the losses in generation would happen in case it needs to operate during the overhaul periods. There are two options:



The HPP Zhur I and HPP Zhur II operate at  $25 \text{ m}^3/\text{s}$  while an overhaul of the other HPP Zhur I TG set is in progress.



HPP Zhur I operates while the overhaul of the HPP Zhur II is in progress.





## 2. TG sets number analysis (cont'd)

In case **alternative 2** (HPP Zhur II with two TG sets ( $2 \times 25 \text{ m}^3/\text{s}$ )) is selected, costs are higher than the Alternative 1 costs for **€ 1,590,300 ( $\approx 1\%$  of Total Investment)**

In order to obtain the cost-benefit ratio for such investment of  $C/B = 1.00$ :  
 + some other reasons (concessionaire!)

For energy price of...	...it is necessary to get a difference in production of...	...which in turn demands that the operation duration in mode with $25 \text{ m}^3/\text{s}$ be...
0.084 €/kWh	1.581 GWh/yr HPP Zhur II with two TG sets would be an	<b>484 hours</b> (34% of the HPP Zhur operating time)
0.110 €/kWh	<b>acceptable solution</b> since the power generation with two TG sets compared to generation with one TG set is lower by only 3 % ( $\eta$ ) 1.207 GWh/yr	<b>370 hours</b> (26% of the HPP Zhur operating time)
<b><math>\geq 0.290 \text{ €/kWh}</math></b>	0.460 GWh/yr	<b>142 hours</b> (10% of the HPP Zhur operating time)

The investment into the HPP Zhur II powerhouse with two TG sets would be justified either if:


1. time of operation in the mode with  $25 \text{ m}^3/\text{s}$  would be considerable, **which is not highly probable**, or
2. the price of energy during its operation in this mode is very high, **which is also not probable**

**The alternative with HPP Zhur II with one TG set,  $Q_i = 50 \text{ m}^3/\text{s}$ , will be selected.**



# project modifications and optimization – the lumi çaljane – plavë reservoir conveyance system

- review of technical concepts from available volume of the 1970 Conceptual Design and their feasibility (site survey 15 Nov 2008), satellite images and available maps)



- the only **route change** that might be needed is a **section near Dragash/Sharr**, in order to avoid the conveyance system passage through the developed area
- the modified route costs are € 822,000 higher
- the **Feasibility Study revision uses the route from the Conceptual Design** and increases the costs by € 822,000, which is maximum increase that might result form conflicts with the existing structures





# project modifications and optimization – the lumi çaljane – plavë reservoir conveyance system

## Conveyance System Concept Analysis

	<i>Conceptual design (1970)</i>	<i>Feasibility Study Revision (2009)</i>
<b>The tunnel capacity is determined on the basis of</b>	<b>15-day</b> discharge duration	<b>5-day</b> discharge duration (15-day discharge duration is analyzed!)
<b>Lumi Çaljane River – Lumi Restelic River Tunnel</b>	D = <b>2.00 m</b>	D = <b>2.90 m</b> (technological reasons!)
	<ul style="list-style-type: none"><li>• <b>20 cm</b> thick <b>plain concrete</b> lining (category I – IV rock)</li></ul>	<ul style="list-style-type: none"><li>• <b>30 cm</b> thick lining (cat. I – III: plain; cat. IV: reinforced);</li><li>• <b>the excavation protection:</b> (cat. I &amp; II – 5 cm shotcrete, cat. III – 10 cm shotcrete + rock bolts, cat. IV – 15 cm shotcrete + rock bolts)</li></ul>



# project modifications and optimization – the lumi çaljane – plavë reservoir conveyance system

## Conveyance System Concept Analysis (cont'd)

	<i>Conceptual design (1970)</i>	<i>Feasibility Study Revision (2009)</i>
<b>Lumi Restelic River – Lumi Brod River Tunnel</b>	D = <b>2.20 m</b>	D = <b>2.90 m</b> (tech. reasons!)
	<ul style="list-style-type: none"><li>• <b>20 cm</b> thick <b>plain concrete</b> lining (category I – III)</li></ul>	<ul style="list-style-type: none"><li>• <b>30 cm</b> thick <b>plain concrete</b> lining</li><li>• <b>the excavation protection:</b> (cat. I &amp; II – 5 cm shotcrete, cat. III – 10 cm shotcrete + rock bolts)</li></ul>





# project modifications and optimization – the lumi çaljane – plavë reservoir conveyance system

## Conveyance System Concept Analysis (cont'd)

	<i>Conceptual design (1970)</i>	<i>Feasibility Study Revision (2009)</i>
<b>Lumi Brod River – Plavë Reservoir Conv. System</b>	D = 2.00, 2.80, 2.85, 2.90 m	D = 2.90, 3.00, 3.00, 3.20 m (respectively) for <b>5-day</b> d. d. (D = 2.90 m for 15-day d. d.)
<p>• increase in the conveyance system (due to 5-day d. d. investment by € 2,500,000, but also increase the HPP Zhur output by 7.45 GWh/yr)</p> <p><b>Lumi Brod River – Plavë Reservoir Conveyance System</b></p> <p>• the analysis results shows that <b>it is justified to increase the conveyance system and tailor its capacity to five-day discharge intake and conveyance</b></p>	<p>• 20, 25, 30 cm thick plain concrete lining (category I – V rock)</p>	<p>• 30 cm thick lining (cat. I – III: plain; cat. IV &amp; V: reinforced);</p> <p>• the excavation protection: (cat. I &amp; II – 5 cm shotcrete, cat. III – 10 cm shotcrete + rock bolts, cat. IV – 15 cm shotcrete + rock bolts cat. V – 25 cm shotcrete + rock bolts + steel arches)</p>



# project modifications and optimization – brezna reservoir

The most significant changes (seventies – today) are those caused by the **Brezna settlement growth in direction of the Fusha e Llopushnikut field**, which had been planned for impoundment for the future reservoir. Rough assessment shows that **about 200 houses** would have to be sacrificed for the reservoir creation.

Brezna Reservoir		979.40 m a.s.l.	970.00 m a.s.l.
<p><b>Is lowering of the reservoir pool elevation possible and what would be the effects?</b></p> <p>In order to collect information on possible effects, the pool elevation lowering by <b>about 10 m</b> was assumed, i.e. from 979.40 m a.s.l. to approx. 970 m a.s.l.</p>			
Houses impounding (Brezna Zym)	Number	≈ 200 + 25 = 225	≈ 180 + 20 = 200
Plavë River dam cost save		€ ±0.00	€ +1,200,000.00
Average annual output	W	398 GWh	391 GWh
Brezna reservoir active capacity		112 hm <sup>3</sup>	65 hm <sup>3</sup>
Uninterrupted operation		26 days	15 days

Therefore, the pool elevation to be used for the Brezna Reservoir will be **979.40 m a.s.l.**, namely the planned reservoir capacity will be the one needed for the **annual flow regulation**.





**The HPP Zhur is the only energy source capable of compensating for outage of any Kosovo A and B TPP units, and partly of the Kosovo C1 new unit. This is the source that will play a key role in tertiary regulation of the Kosova Power System, and in the electricity market by ensuring guaranteed power supply**

**...THE 110 kV NETWORK**

- two two-circuit conductors ("barrel-type") with conductors of sufficient cross-section ACSR 240/40

**...THE 220 kV NETWORK**

- one two-circuit conductor ("barrel-type") with conductors ACSR 490/60 cross-section

**The HPP Zhur can be interconnected with either 110 kV or 220 kV network.**

- the investment price for the 2x110 kV HPP Zhur I–Prizreni 2 OHL is **3,520,000 €**

- the HPP Zhur II connection price to 220 kV network is **3,800,000 €**

**The nearest network connection point in both cases is the 220/110 kV Prizreni 2 Substation.**

- the investment price for 110 kV OHL, 2.3 km, ACSR 240/40, between the HPP Zhur I and HPP Zhur II is **253,000 €**

- OHL 220 kV, 2.3 km, ACSR 490/60, between HPP Zhur I and HPP Zhur II – **460,000 €**

**The interconnection length in both cases is 10 km. The conductor length between the HPP Zhur I and HPP Zhur II is 2.3 km.**

- it is necessary to add ten 110 kV transformer bays – **4,000,000 €**

- it is necessary to add six 220 kV transformer bays – **3,300,000 €**

- **TOTAL INVESTMENT: 7,773,000 €**

- **TOTAL INVESTMENT: 7,560,000 €**

The price difference between the connection to the 110 kV and 220 kV networks **is not significant**



## HPP ZHUR IS INTERCONNECTED TO...

### ...THE 110 kV NETWORK

- design losses on the power system model:  
**22.4 MW**

#### ADVANTAGES:

- relieving of the transformation load at the 220/110 kV Prizreni 2 Substation
- better maintenance of the voltage profile
- reduction in network losses

### ...THE 220 kV NETWORK

- design losses on the power system model:  
**20.3 MW**

#### ADVANTAGES:

- a logical connection level for a power plant of this capacity
- enables its minimum effect on possible shallow connections
- enables its operation as the peaking plant

According to the KOSTT expectations, **the 220 kV network will not develop further, and a 400 kV ring with transformations of 400/110 kV would be closed.** This would resolve the supply of the 110 kV network, so **connecting of the HPP Zhur to the 220 kV is justified.**

- In request for the HPP Zhur connection in transmission power system of Kosova, according the Energy Regulatory Office and KOSTT rules will have to met:
  1. **Rule on General Conditions of Energy Supply (2008)**
  2. **Grid Code — Connection Code (2008)**
  3. **Transmission Connection Charging Methodology (2008) and UCTE rules**





		Zhur 1 HPP	Zhur 2 HPP
Gross head [m]	max.	<b>589.40</b>	<b>94.15</b>
	min.	<b>555.25</b>	<b>87.94</b>
Net head [m]	max.	<b>583.93</b>	<b>93.52</b>
	min.	<b>533.38</b>	<b>85.41</b>
No. of TG sets		<b>2</b>	<b>1</b>
Rated discharge [m <sup>3</sup> /s]		<b>2 × 25</b>	<b>1 × 50</b>
Installed capacity [MW]		<b>2 × 131</b>	<b>1 × 43</b>
Average annual output [GWh]		<b>342.20</b>	<b>55.39</b>
		<b>397.59</b>	



## summary expenses

<b>Item</b>	<b>Costs [€]</b>
Land (Site)	<b>29,824,000</b>
Civil structures	<b>126,890,000</b>
Hydromechanical equipment	<b>33,441,000</b>
Electromechanical equipment	<b>70,071,000</b>
Transmission and distribution lines	<b>6,196,000</b>
Other investment	<b>20,593,000</b>
<b>Total capital assets</b>	<b>287,017,000</b>